



DYACON®



**TPH-1
(Temperature-Pressure-
Humidity)
Sensor MANUAL**

57-6018 Rev B

Contents

NOTICES.....	4
© Copyright 2013 Dyacon, Inc.....	4
Manufacturer.....	4
Declarations.....	5
Warranty Information.....	5
TPH-1 INTRODUCTION.....	7
Scope.....	7
Technical Support.....	7
Contact Information.....	7
Phone / Email Support.....	7
PRODUCT OVERVIEW.....	8
Product Description.....	8
What Do You Get?.....	9
What You Need.....	9
Accessories.....	10
ASSEMBLY INSTRUCTIONS.....	12
Required Tools.....	12
Mounting Bracket.....	12
Wiring.....	13
Additional Assembly Images.....	14
MODBUS.....	15
Modbus Summary.....	15
Modbus Utilities.....	15
Modbus Commands.....	16
Data Format.....	19
Temperature Format.....	19
Humidity Format.....	19
Pressure Format.....	19
Pressure Trend.....	19
Conversions and Calculations.....	20
Barometric Pressure at Mean Sea Level.....	20
Pressure Unit Conversion.....	20
Temperature Conversion.....	20
THEORY OF OPERATION.....	21
Sensors.....	21
Temperature.....	21
Pressure.....	21
Humidity.....	21
Architecture.....	21
POWER SAVING.....	22
Run Timeout Power.....	22
Wake and Sleep Operation.....	22

Power Down.....	23
SOFTWARE.....	24
Introduction.....	24
Boot Loader.....	24
Required Equipment.....	24
Procedure.....	24
REPAIR AND SERVICE.....	25
Parts List.....	25
Repair and Calibration.....	25
SPECIFICATIONS.....	26
MODBUS APPENDIX.....	27
REVISION HISTORY.....	29

NOTICES

© Copyright 2013 Dyacon, Inc.

All Rights Reserved

This publication is protected by copyright and all rights are reserved. Any reproduction of this manual, in part or in full, by any means, mechanical, electronic, or otherwise, is strictly prohibited without express written permission from Dyacon, Inc.

The information in this manual has been carefully checked and is believed to be accurate. However, Dyacon, Inc. assumes no responsibility for any inaccuracies that may be contained in this manual. All information is subject to change.

Trademark Acknowledgments

DYACON® and Dyacon® is a registered trademark of Dyacon, Inc.

DYACON, TPH-1™, TPH™ are trademarks of Dyacon, Inc.

All other trademarks are property of their respective owners.

Manufacturer

Dyacon, Inc.
220 West 300 South
Newton, UT 84327
USA

Declarations

DYACON TPH-1™ is a low-power electronic industrial device.

RoHS

All electronic and mechanical components conform to RoHS, Directive 2002/95/EC.

FCC CFR Part 15

This equipment complies with the limits for a Class A digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a commercial installation.

Warranty Information

Limited Hardware Warranty

Dyacon, Inc. warrants that all DYACON products and components shall be free from defects in materials and workmanship for a period of one (1) year from the date of shipment when installed according to instruction manuals accompanying said hardware and used for the purpose for which said hardware was designed. In the event a defect in materials or workmanship is discovered and reported to Dyacon within the warranty period, Dyacon will at its option repair the defect or replace the defective product. This warranty does not apply where the product has been operated outside the specifications of the product. Dyacon's obligation hereunder will be limited to such repair or replacement. Customers shall have the responsibility to ship the defective equipment to Dyacon at its (customer's) expense, with all cost of shipment prepaid. Dyacon will ship the repaired or replaced item at its (Dyacon's) expense using the preferred shipment method of Dyacon.

Disclaimer of Warranties

The warranties set forth above are in lieu of all other warranties of Dyacon, whether written, oral, or implied. Dyacon makes no warranties regarding its products (hardware or software), including without limitation warranties as to merchantability, fitness for a particular purpose, any warranty arising from course of performance, course of dealing or usage of trade whether any of the foregoing warranties are either expressed or implied. Dyacon specifically makes no warranties as to the suitability of its products for any particular application. Dyacon shall in no event be liable for performance, or use of any product covered by this agreement whether such claim is based upon warranty contract (express or implied), strict liability, negligence, or otherwise. Any responsibility and/or liability of Dyacon shall, in connection with a warranted product, be limited in maximum amount to the original purchase price of that product.

Removal of Serial Number

Removal of the original serial number label or reprogramming of the electronic serial number voids any warranty on the device. Dyacon will not repair or update products if the serial number label missing or legitimate ownership cannot be verified. Dyacon may not return equipment that is missing serial numbers or where legitimate ownership is in question.

Updates or Modifications

Dyacon shall be under no obligation to update or modify its products except as herein noted to correct defects or errors. Customer agrees that all representation and warranties contained herein shall be immediately null and void in the event of any incorrect installation, modification, alteration, or change in or to any product affected by or on behalf of customer except for a change made by Dyacon or other direct supervision thereof.

TPH-I INTRODUCTION

Scope

The content of this document is intended for integrators, installers, and users of TPH-1™, hereinafter referred to as TPH or “air sensor”.

This document includes installation instructions, technical specifications, electrical requirements, and data protocol information. Some aspects of the equipment operation may be covered in other documents. Please contact Dyacon or visit the DYACON.com website.

Technical Support

Contact Information

Dyacon, Inc.

220 West 300 South
Newton, UT 84327

Phone: (435) 753-1002

Email: support@dyacon.com

Internet: www.DYACON.com

Normal business hours are from 8:00 am to 5:00 pm. (Mountain Time Zone, GMT -0700)

Phone / Email Support

If you need technical support via the phone or email, please have the following information ready:

Product name, model number, and serial number.

Your name and name of the purchaser of the equipment.

Name of company, institution, or agency.

Phone number, email address.

Billing and Shipping address.

A clear description of the question or problem.

PRODUCT OVERVIEW

Product Description

DYACON TPH-1™ is an integrated air sensor, measuring air temperature, barometric pressure, and relative humidity in a single package. The air sensor may be used as a standalone sensor, a component of DYACON weather station, or integrated into other automated equipment.

TPH-1 is a digital sensor, sending instrument data and receiving control commands via a digital serial port using Modbus-RTU protocol over TIA-485-A (RS-485). Consequently, there is no measurement degradation due to cable length.

TPH-1 is easily mounted to the end of a 1” pipe using simple tools and standard structural pipe fittings.

Sensor Protocol Descriptions

Modbus-RTU (RS-485) is an electrically robust protocol used in automation systems, such as programmable logic controllers (PLCs). TPH uses a default data rate of 19200 bps, ensuring adequate data throughput while extended cable length capability.

An SDI-12 version is available as TPH-2.

Additional firmware and customization options are also available to VARs. Contact Dyacon, Inc. for more information.

Mechanical Design

The mechanical design for TPH-1 was designed to meet the following objectives.

- Minimize installation hardware and complexity – A simple band clamp is all that is required, providing a fast and secure mounting system.
- Minimize cable routing vulnerability – The cable can be routed directly adjacent to or inside of the mounting pipe.
- Allow for easy sensor replacement – The lower radiation shield separates from the mounting bracket with three wing nuts, exposing the sensor board.
- Separate the sensor from thermal sources on mounting structure – A horizontal mounting pipe allows users to offset the sensor from the structure at a convenient distance.
- Provide an air duct for aspirated version – An aspiration kit is available in either push or pull configurations to improve accuracy in still air or direct sun conditions.
- Maintain mechanical simplicity – The system can be easily disassembled and repaired in the field.
- Reduce thermal mass – UV-stabilized PC/ABS construction and minimal hardware, reduce the thermal effects of the sensor assembly.

What Do You Get?

TPH-1 ships with:

- Radiation shield assembly
- Mounting bracket
- Sensor board with 2 m cable
- Stainless steel band clamp



Image 1: TPH-1, As-shipped

What You Need

In order to utilize the TPH-1 you will need the following.

- 1" diameter mounting pipe (aluminum, steel, or PVC, 1.32 inch actual outer diameter).
- 5 to 24 VDC power supply.*
- Modbus host device.*

* Not required if using the TPH-1 with a DYACON control module.

Accessories

Mounting Pipe (Option)

A 1 m aluminum pipe is available from DYACON. The pipe has been cut to act as an aspiration conduit for the aspiration kit or the TPH-2.

The angled cut and the pipe provide an air conduit for the aspiration kit. The cut also allows for the instrumentation cable to be routed through the mounting pipe. For some installations this provides additional cable protection and a cleaner looking installation.

Customers may also fabricate their own mounting pipe from aluminum, steel, or PVC schedule 40 pipe to meet their needs. The dimensions are provided below.




Image 2: Mounting Pipe Dimensions

Pipe Mounting Bracket (Option)

The lightweight mounting bracket shown below is used with band clamps to hold a pipe on a flat surface or tower pipe. The bracket details are available on the DYACON.com website.




Image 3: Lightweight Mounting Bracket

Structural Pipe Fittings

Standard structural pipe fittings for 1" schedule 40 pipe are available from hardware suppliers and manufacturers.

Hollaender Nu-Rail (www.nurail.com)

J.C. Denier (www.denierco.com)

Easyfit (www.easyfit.com)

Diamond Aluminum (www.diamond-aluminum.com)

KEE Systems (www.keesystems.com)

McMaster-Carr (www.mcmaster.com)

Grainger (www.grainger.com)



ASSEMBLY INSTRUCTIONS

Required Tools

- 8 mm (3/8 inch) wrench or socket or slotted screw driver for band clamp
 - Wire cutters to trim cable ties.
-

Mounting Bracket

The mounting bracket is designed to fit on a 1" schedule 40 pipe, 1.315" OD.

The mounting bracket is pre-assembled to the radiation shield.

1. Slide band clamp and mounting bracket onto the 1" pipe. Observe wire route shown in image. Take care to avoid cutting or pinching the cable when the inserted on pipe.



Image 1: Mounted showing cable routing.

The cable may be routed inside of the mounting pipe if cut according to the dimensions shown in Image 2.

2. Tighten band clamp over the end of the mounting bracket.
3. Attach wire ties every 12 to 18 inches (30 to 45 cm) along the mounting pipe.




Image 2: Mounted showing cable tie.

Wiring

TPH-1 ships with shielded, 4-conductor, outdoor-rated instrumentation cable.

Red – 5 to 24 VDC

Orange – A (+)

Brown – B (-)

Black – Electrical ground

Bare – Earth Ground (Shield)




Image 3: Wired for DYACON Control Module

Additional Assembly Images

Cable Route and Internal Cable Tie



TPH-1 Disassembled



MODBUS

Modbus Summary

Modbus is a simple protocol that can be transmitted over several modes including TCP/IP, TIA-232-A (RS-232), TIA-485-A (RS-485), TCP/IP, SMS, and many others.

DYACON TPH-1 uses Modbus-RTU over RS-485.

TPH-1 is a slave device and must be connected to a host device, such as a programmable logic controller (PLC), host computer with an RS-485 adapter and Modbus software, or to the DYACON weather station control module.

RS-485 is a robust, differential pair electrical protocol that is noise immune and capable of long cable runs. With twisted pair cabling, such as CAT-5, distances over 1200 m (4,000 ft) can be achieved. TPH-1 can be configured for 1200 bps or 2400 bps to extend the range. Relatively long runs are achievable even without twisted pair cables.

The wide operating voltage range and low power of TPH-1 allows for power to be injected over the same data cable without concern for excess voltage drop. (Two wires for power and two for data.)

For example, 1200 m (4000 ft) of Cat-5 cable (24 AWG) will result in a voltage drop of less than 0.2 V at an operating current of 2 mA.

TPH-1 ships standard with 2 m (6.5 ft) of non-paired cable.

Modbus Utilities

The address of the sensor and other parameters are configurable. A Modbus computer utility may be required to change these settings. A number of utilities are available including:

ModBusConstructor by KurySoft (www.kurysoft.com)

Simply Modbus (www.simplymodbus.ca)

ModbusTools (www.modbustools.com)

Only ModBus Constructor and the companion Modbus Reader have been tested with the DYACON product.

A list of Modbus software can be found at: www.modbus.org/tech.php

Modbus Commands

TPH contains a Modbus slave port, the Modbus host must requests data from the sensor.

The following describes the Modbus commands and messages. The basic instructions should be adequate for Modbus host programming. For embedded developers, additional protocol details are contained in the Modbus Appendix.

The default configuration:

Modbus address 02
 Serial Data Parameters 19200, 8-bit data, no parity, 1 stop bit

Supported Functions and Exception Codes

Function	Description	Supported Error and Exception codes*
3	Read Holding Register	0x83: 01, 02, 03, 04
4	Read Input Register	0x84: 01, 02, 03, 04
6	Write Single Register	0x86: 01, 02, 03, 04
16	Write Multiple Registers	0x90: 01, 02, 03, 04

* See Error Code table below for more information.

Sensor Data Requests

Address	Register	Access Type	Response Range	Data Type	Description
200	201	Read	0 to 3	16-bit Signed Int	System Status†
201	202	Read	-400 to 1250*	16-bit Signed Int	Temperature (Celsius)
202	203	Read	0 to 1000*	16-bit Signed Int	Relative Humidity (%)
203	204	Read	0 to 13100*	16-bit Signed Int	Pressure (mbar)
204	205	Read	-2, -1, 0, 1, 2*	16-bit Signed Int	Pressure Trend

† See System Status Code section below.

* See Data Format section for numeric conversions.

TPH-1 requires about 70 ms to read sensor elements and respond.

Basic Configuration Messages

The following commands can be used to change the serial port parameters of the air sensor.

Address	Register	Access Type	Range	Data Type	Description
100	101	Read		16-bit Signed Int	MM = Product ID YY = Product Variation
101	102	Read		16-bit Unsigned Int	Serial Number
102	103	Read		16-bit Signed Int	Firmware Version
103	104	Read/Write	1-247 Default: 1	16-bit Signed Int	Modbus slave address.
104	105	Read/Write	0 = 1200 bps 1 = 2400 bps 2 = 4800 bps 3 = 9600 bps 4 = 19200 bps 5 = 38400 bps Default: 4	16-bit Signed Int	Baud rate.
105	106	Read/Write	0 = None 1 = Odd 2 = Even Default: 0	16-bit Signed Int	Parity
106	107	Read/Write	0 to 10,000 Default: 0	16-bit Signed Int	Run Timeout. Duration in ms before TPH-1 returns to sleep. Zero (0) is full-run mode.*

* Refer to Power Saving section for more details.

Calibration Settings

Calibration values are entered as slope and offset (mx+b). The following calibration settings are user accessible.

Address	Register	Access Type	Default	Data Type	Description
110	111+112	Read/Write	1	32-bit Single-precision Float*	Temperature Slope
112	113+114	Read/Write	0	32-bit Single-precision Float	Temperature Offset
114	115+116	Read/Write	1	32-bit Single-precision Float	Humidity Slope
116	117+118	Read/Write	0	32-bit Single-precision Float	Humidity Offset
118	119+120	Read/Write	1	32-bit Single-precision Float	Pressure Slope
120	121+122	Read/Write	0	32-bit Single-precision Float	Pressure Offset

* 32-bit single-precision floating point (IEEE-754) numbers are restricted to about 7 significant decimal figures. 32-bit values are transmitted most significant word (MSW) first.

Error Codes

The following error and acknowledgment codes are supported by the TPH-1. Not all codes are relevant to each request or command. Supported command error codes are listed for each command.

Function	Name	Description
01	Illegal Function	Function not supported or not recognized by the sensor.
02	Illegal Addresses	Incorrect address, address does not exist, or address does not support write function.
03	Illegal Data Value	Data value is outside of allowed range.
04	Device Failure	Error occurred while attempting to perform the requested action.

System Status Codes

System status codes are unique to the sensor, not Modbus protocol exceptions. System codes are bit codes representing internal functional errors. A clear (0) bit indicates no errors were detected. A set (1) bit indicates an error.

Contact customer support if system errors are encountered.

Bit	Name
0	Temperature/Humidity sensor error
1	Pressure sensor error

Hex Values

0x0000 – No Errors

0x0001 – Temp sensor error

0x0002 – Pressure sensor error

0x0003 – Temp and pressure sensor errors

Data Format

TPH-1 delivers instrumentation data as signed integers. Consequently, numeric conversion is required to determine the decimal values.

When TPH-1 is used with DYACON control modules, the instrument data is automatically presented in the form of standard units and ranges.

When TPH-1 is used with a PLC or other host device, the instrumentation data will need to be numerically converted to conventional units.

Temperature Format

The measured temperature range is -40.0°C to 125.0°C.

The Modbus data range is -400 to 1250.

$$\text{Temperature (}^\circ\text{C)} = (\text{ModbusData}) / 10$$

Humidity Format

The measured relative humidity range is 0.0% to 100.0%.

The Modbus data range is 0 to 1000.

$$\text{Relative Humidity (\%)} = \text{ModbusData} / 10$$

Pressure Format

The measured atmospheric pressure range is 0.0 mbar to 1300.0 mbar

The Modbus data range is 0 to 13000.

$$\text{Atmospheric Pressure (mbar)} = \text{ModbusData} / 10$$

Refer to the Barometric Pressure at Mean Sea Level for more information.

Pressure Trend

Pressure trend indicates the direction of change over the last three hours.

The trend value is assigned according to the following rules:

Value	Indication	Description
-2	Falling rapidly	Decrease of more than 2 mbar (0.06 inHg)
-1	Falling slowly	Decrease of 1 mbar to 2 mbar (0.02 inHg to 0.06 inHg)
0	Steady	Change of less than 1 mbar (0.02 inHg)
1	Rising slowly	Increase of 1 mbar to 2 mbar (0.02 inHg 0.06 inHg)
2	Rising fast	Decrease of more than 2 mbar (0.06 inHg)

Conversions and Calculations

Barometric Pressure at Mean Sea Level

For comparative measurements, barometric pressure given in weather reports is normalized to mean sea level (MSL).

To determine the barometric pressure relative to mean sea level, Babinet's formula can be used:

$$\text{Barometric Pressure (mbar)} = P * ((16000 + 64 * T) + Z) / ((16000 + 64 * T) - Z)$$

where:

P = atmospheric pressure (mbar)

Z = altitude (m)

T = temperature (°C)

This simple formula will give good results within up to 1000 m (3280 ft) and within 1% to much greater heights.

Pressure Unit Conversion

$$\text{Pressure (inHg)} = \text{Pressure (mbar)} * 0.02953$$

Temperature Conversion

Unit conversion can be done by utilizing the slope and offset feature or applying the following formulas to the TPH-1 formatted data.

$$\text{Temperature (°F)} = \text{Temperature}^{\circ}\text{C} * 1.8 + 32$$

Conversion Tip

TPH-1 contains calibration registers that can be used for conversion. Just enter the desired conversion values shown above into the slope and offset registers for pressure or temperature.

Please be aware, that this may complicate any calibration adjustments that may have to be applied later. However, most users will find that the calibration is not necessary.

THEORY OF OPERATION

Sensors

Temperature

A PTAT sensing element in the digital sensor has a resolution of 0.015°C and accuracy of +/-0.2 K.

Error and range checking is done to ensure accurate results.

The temperature sensing element is protected from direct moisture contact.

Pressure

The high-resolution digital pressure sensor utilizes MEMS technology to deliver +/-1.5 mbar accuracy at 25°C and +/-2.5 mbar over the operational temperature range.

The sensor has a measurement resolution of 0.01 mbar, but Modbus resolution is 0.1 mbar.

Humidity

Relative humidity is measured with a digital sensor employing a capacitive polymer sensing element.

Sensor resolution is 0.02% rH, but reported at 0.1% in Modbus reports.

Error and range checking is performed to ensure accurate results.

Architecture

A range of low power strategies are employed in TPH-1 to ensure optimal low power while providing reliable and accurate measurements across the full environmental range.

A low power microcontroller is central to TPH-1 performance. The microcontroller manages the sensors, performs error tests, scaling, calibration, and low-level unit conversion as required. The microcontroller also manages the Modbus protocol and other internal functions, such as EEPROM interface and bootloader functions.

The microcontroller utilizes low-power strategies, leveraging multiple low power modes and optimized code execution.

POWER SAVING

Run Timeout Power

TPH-1 can be optimized for battery powered applications. The Run Timeout setting can be used to reduce the average operating current.

Sleep mode is controlled with the “Run Timeout” parameter. By default, the value is set to zero (0), full run mode. The default setting will be applicable for most programmable logic controllers (PLCs) since these applications are typically line powered and will not significantly benefit from power optimization.

Embedded devices and data loggers may have the programming flexibility to utilize the Run Timeout function.

Although the Run Timeout parameter range is 0 to 10000 (0 s to 10 s), the minimum actual timeout is 50 ms. Values below 50 will result in a 50 ms run time before entering sleep mode. This is a safe guard to prevent a device from becoming un-wakeable because of message transmission latency.

Sleep Power Example

When powered at 12 VDC and a 1 s pole rate:

Run Timeout = 0 (Full Run Mode) 1.7 mA

Run Timeout = 100 < 0.45 mA

While small, the sleep power reduction can accumulate to a significant amount for a battery operated instruments. A savings of 30 mAh per day can extend system operating time and improve power budget flexibility.

Wake and Sleep Operation

Run Timeout is a millisecond (ms) count from the end of the last communication frame to initiation of sensor sleep. In other words, if Run Timeout is set to 150 the sensor will go to sleep 150 ms after the last character of a frame is received or transmitted.

TPH-1 returns to full run mode when a character is received on the Modbus data port. Due to the latency in returning to full run mode, the first few characters of the Modbus data frame will be lost. If a Modbus packet is used to wake the sensor, it will need to be resent.

Following a “wake” packet, the Run Timeout value must be sufficiently long for the host to send a data request or instruction before TPH-1 returns to sleep.

Embedded devices and programmable data loggers can send a character to wake the sensor. A Modbus broadcast message can be used for this purpose. A delay of only 4 ms from the first bit is required before sending a Modbus request.

TPH-1 will wake from any character on the RS-485 data bus. If TPH-1 is one of several devices on the data bus, it will wake even when other devices are addressed.

Power Down

Embedded devices and programmable data loggers may have discrete power controls to peripheral devices. If so, additional power savings may be achieved by disconnecting the supply power to TPH-1. This strategy may be practical if the polling period is longer than 1 s.

The time required from power-up to first character is less than 100 ms. Modbus frames sent prior to this may not be received by the sensor.

SOFTWARE

Introduction

TPH-1 is a digital sensor with on-board firmware. The firmware provides critical functions including sensor element interface, sensor value processing, calibration scaling, error detection, power management, and Modbus operation. The firmware also includes a boot loader for in-field firmware changes.

Boot Loader

TPH-1 firmware may be updated in the field through the RS-485 serial data lines.

Required Equipment

- RS-485 to USB (or RS-232) converter.
- 12 VDC power supply.
- DYACON Boot Loader PC utility.
- TPH-1 firmware (.hex) file.

Procedure

1. Disconnect TPH-1 from the host equipment.
2. Connect the TPH-1 to the PC with the RS-485 converter.
3. Connect TPH-1 to a 12 VDC power source.
4. Run the DYACON Boot Loader Utility. Configure the settings and press “Load.”
5. Watch for program completion.
6. Disconnect and return the TPH-1 to service.

REPAIR AND SERVICE

Parts List

Part Number	Description
17-6000	HRD, Hose Clamp, 1 to 2 in x 0.5 in, Worm Gear, SS
17-6015	CABLE TIE, 2.4 x 102 mm, Nylon, Heat Stabl, SS barb, Black
17-6059	NUT, 6-32, 5_16 Hex, 18-8 SS
17-6060	WING NUT, 6-32, 18-8 SS
51-6011	ASSY, Sensor, Temp-Hum, 2 m Outdoor Cable
75-6043	Plate, Top, Rad Shield
75-6044	Plate, Rad Shield
75-6045	Bracket, Mounting, Rad Shield
75-6046	Probe, Air Sensor
75-6056	ROD, Threaded, 6-32 x 4.5 in, 18-8 SS

Repair and Calibration

Return Authorization

All equipment sent to Dyacon for calibration, warranty, or service should have a return material authorization (RMA) number indicated on the outside of the package. Include a detailed description of the problem and any to be performed on the returned unit.

An RMA number may be requested by phone or email.

Phone: 1-435-753-1002

Email: support@DYACON.com

Normal business hours are 8 am to 5 pm. (Mountain Time Zone, GMT -0700)

Street Address

Dyacon, Inc.
220 West 300 South
Newton, UT 84327

US Mail Addresses

Dyacon, Inc.
PO Box 33
Newton, UT 84327

SPECIFICATIONS

TEMPERATURE

Range	-40°C to 80°C
Resolution	0.05°C
Accuracy	+/- 0.2 K*
Reproducibility	+/- 0.1 K
Response Time	12 s
Long Term Drift	< 0.05 K/yr
Sensor Type	PTAT

RELATIVE HUMIDITY

Range	0% to 100% RH
Resolution	0.1% **
Accuracy	+/- 1.8% (0 to 80
Reproducibility	+/- 0.2% RH**
Hysteresis	< +/- 1% RH
Linearity	< +/- 1% RH
Response Time	12 s
Long Term Drift	<0.5% RH/yr
Sensor Type	Capacitive

BAROMETRIC PRESSURE

Range	10 mbar to 1300 mbar
Resolution	0.065 mbar*
Accuracy	+/- 1.5 mbar
Response Time	0.5 ms
Long Term Stability	<1 mbar/yr
Sensor Type	MEMS – 24-bit

*Full response range information available upon request.

** Actual sensing element resolution is 0.02%, but only reported as 0.1 increments.

ELECTRICAL

Power Input	5 to 24 VDC (12 VDC Nominal)
Current	1.4 mA _{avg} at 14 VDC full run mode [†] 0.06 mA _{avg} sleep mode [‡]

MECHANICAL

Material	PC/ABS, UV-Stabilized, white
Overall (WxDxH)	13.2 x 13.4 x 13 cm (5.2 x 5.2 x 5.1 in)
Cable	4 conductor, 24 AWG, stranded Foil Shield w/ drain wire Outdoor rated cable
Total Weight	288 g (10.2 oz)
Weight Shield Only	228 g (8.1 oz)

DATA

Protocols	Modbus slave SDI-12 option (value added resellers)
OEM Options	Packet structure Packet content

Temperature

Operating Temperature	-40°C to 80°C
Storage Temperature	-40°C to 80°C

ACCESSORIES

Aspiration	Smart-Fan [™] aspiration kit
Structural Fittings	Lightweight cross-over
Structural Pipe	1" x 1 m (3.1 ft)

[†] Continuous full run mode, reading 200 range registers once per second.

[‡] Timeout set to 50 or greater. No Modbus activity.

MODBUS APPENDIX

DYACON TPH-1 air sensor uses Modbus RTU format. The following are the protocol details required for embedded devices to communicate with the Modbus sensor.

- Modbus data uses “big-endian” data format, 0x1234 is sent as 0x12 then 0x34.
- The CRC uses “little-endian” data format, 0x1234 is sent as 0x34 then 0x12.
- The idle time between frames must be greater than or equal to 3.5 characters. The frame inter character delay must be less than 1.5 characters.
- The PDU Registers are addressed starting at zero. Therefore a register numbered as 201 is addressed as 200.

The following is an example of a multi-register read of the air temperature, humidity, and pressure starting at register number 202.

Detailed protocol information is available at www.modbus.org.

Request Frame

The following is an example of a read of the air temperature, humidity, and pressure with one request.

Field Name	Length (bytes)	Function	Example Data
Slave Address	1	Device address.	0x02
Function	1	Read holding register.	0x03
Register Start Address	2	Sensor address (201).	0x00C9
Quantity of Registers	2	Number of 16-bit registers to read.	0x0003
CRC	2	Error check.	0xC6D5

TX String (0x): 02 03 00 C9 00 03 D5 C6

Response Frame

Field Name	Length (bytes)	Function	Example Data
Slave Address	1	Device address.	0x02
Function	1	Read holding register.	0x03
Byte Count	1	Number (N) of data bytes.	0x06
Register Data	N	Register data, upper byte first. Register 202 (Temp): 325 (32.5 °C) Register 203 (Rel. Hum.): 689 (68.9%) Register 204 (Pressure): 8526 (852.6 mbar)	0x0145 0x02B1 0x214E
CRC	2	Error check.	0x6030

RX String: 02 03 06 01 45 02 B1 21 4E 30 60

Error Frame

Field Name	Length (bytes)	Function	Example Data
Slave Address	1	Device address.	0x02
Error Code	1	Error code value.	0x83
Exception Code	1	Error code values (01, 02, 03, 04)	0x01
CRC	2	Error check	0xF070

TX String: 02 83 01 70 F0

REVISION HISTORY

Rev	Description	Author	Date
A Prelim	Initial Release	E. Bodrero	19NOV2013
B	Brand update, minor formatting, and specifications. Add pressure trend (firmware Rev C/v4)	E. Bodrero	30JUN2014